

CORRIGENDUM (NO. 1)

**AMENDMENTS TO TENDER DOCUMENTS APPROVED BY MUTUAL
CONSENSUS DURING PRE-BID MEETING ON 23.01.2023 AT 1100 HOURS
FOR FITMENT 75 HIGH MAST LED 500W ON EXISTING MAST.**

1. The following time lines may kindly be amended in the Tender document.

- a) Item No. 8 (C) Submission on bid's
For : 05:00 pm on 27.01.2023
Read: 05:00 pm on 28.01.2023
- b) Item No. 8 (D) Opening of Technical Bid
For : 11:00 am on 28.01.2023
Read: 11:00 am on 31.01.2023
- c) Item No. 11 Completion of work
For : 30 Days
Read: 45 Days

**Rest No
Change**

- 2. All the LED Fixtures should be 465 watt and above and IP-66, IK-08, BIS Approved, 125 Lumen & above/Watt, LM-79 & LM-80 report approved form EVTL/NABL and reputed labs with copy attached to Technical Bid.
- 3. The Vendor will be responsible to carry out site visit and ensure Technical feasibility of the Proposal as per specification given by PCA.
- 4. The Vendor will submit an AuthorizationCertificate from OEM & enclosed the same alongwith the Technical Bid.
- 5. The details of the existing layout of Bajaj High Mast handed over to Vendors and being emailed.